

28 May 2013

Insight Unlimited
PO Box 780
Christchurch 8140

Attn Mr Alan Brown

Dear Alan

BUILDING PROFILE RE-SURVEY OUR CITY - 159 OXFORD TCE

We have now completed the resurvey of 'Our City' building on Oxford Terrace, and the results are included in this attachment.

Following on from the original survey of 29th May 2012, the same methodology was adopted - the positions on the face of the building were all surveyed by Direct Reflective methods with both left and right instrument readings being recorded. Distances were reduced to the horizontal - the same positions were surveyed on the second visit (07 May 2013) - we have shown the repeat measurement in parenthesis.

As you can see, the second follow up survey detected no movement – movements were within survey limits (WSL) +/-3mm. There is one exception being the upper north corner on the East elevation (sheet 08/2). We re-measured this value and checked our original survey for any discrepancy. It could be that a single brick has moved during the period between the 2 surveys. We do not believe that the wall has moved in any way, as the profile below this upper measurement is within survey limits.

The Kate Sheppard National Memorial was surveyed again. The values measured and reduced compare within survey limits of the original survey.

Please feel free to contact us if you have any queries.

Kind Regards



Paul Durkin
Regd Surveyor