

Aug - Oct 2007		POND SIX	POND SIX	POND SIX
		Enterococci	E.coli	Faecal Coliforms
Day	Date	MPN/100ml	CFU/100ml	CFU/100ml
Thursday	02.08.2007	31	4100	5200
Monday	06.08.2007	52	1200	2100
Thursday	09.08.2007	52	110	930
Monday	13.08.2007	53	500	2200
Thursday	16.08.2007	51	470	900
Monday	20.08.2007	21	350	525
Thursday	23.08.2007	10	70	90
Monday	27.08.2007	<10	20	120
Thursday	30.08.2007	<10	300	140
Monday	03.09.2007	20	630	500
Thursday	06.09.2007	10	1000	1300
Monday	10.09.2007	<10	290	440
Thursday	13.09.2007	<10	100	140
Monday	17.09.2007	10	680	700
Thursday	20.09.2007	85	5800	6700
Monday	24.09.2007	<10	460	940
Thursday	27.09.2007	10	4200	7800
Monday	01.10.2007	<10	650	2100
Thursday	04.10.2007	<10	1200	1400
Monday	08.10.2007	<10	91	130
Thursday	11.10.2007	<10	130	130
Monday	15.10.2007	<10	91	130
Thursday	18.10.2007	<10	130	130
Monday	22.10.2007	10	<10	10
Thursday	25.10.2007	<10	50	50
Monday	29.10.2007	<10	40	<18

Consent Requirements Condition 16(d)

Based on twice weekly sampling no more than 6 values from 8 consecutive samples shall exceed the following standard values and no more than 2 values from 8 consecutive samples shall exceed the higher value.

	Standard Value		
	Summer	Winter	Winter
Faecal Coli MPN/100ml	5000	20,000	30,000

