

Nov - Jan 2009		POND SIX	POND SIX	POND SIX
		Enterococci	E.coli	Faecal Coliforms
Day	Date	MPN/100ml	CFU/100ml	CFU/100ml
<i>Thursday</i>				
<i>Monday</i>	03.11.2008	10	<20	100
<i>Thursday</i>	06.11.2008	10	30	110
<i>Monday</i>	10.11.2008	<10	<20	20
<i>Thursday</i>	13.11.2008	<10	<20	<20
<i>Monday</i>	17.11.2008	<10	110	110
<i>Thursday</i>	20.11.2008	10	70	130
<i>Monday</i>	24.11.2008	10	20	60
<i>Thursday</i>	27.11.2008	<10	80	130
<i>Monday</i>	01.12.2008	20	160	110
<i>Thursday</i>	04.12.2008	110	220	200
<i>Monday</i>	08.12.2008	73	<20	100
<i>Thursday</i>	11.12.2008	<10	100	160
<i>Monday</i>	15.12.2008	41	430	320
<i>Thursday</i>	18.12.2008	20	36	260
<i>Monday</i>	22.12.2008	20	500	320
<i>Thursday</i>	25.12.2008	<10	280	220
<i>Monday</i>	29.12.2008	10	220	300
<i>Thursday</i>	01.01.2009	51	200	280
<i>Monday</i>	05.01.2009	41	220	220
<i>Thursday</i>	08.01.2009	41	210	120
<i>Monday</i>	12.01.2009	300	260	210
<i>Thursday</i>	15.01.2009	31	140	180
<i>Monday</i>	19.01.2009	190	210	860
<i>Thursday</i>	22.01.2009	84	200	40
<i>Monday</i>	26.01.2009	180	290	370
<i>Thursday</i>	29.01.2009	140	560	460

Consent Requirements Condition 16(d)

Based on twice weekly sampling no more than 6 values from 8 consecutive samples shall exceed the following standard values and no more than 2 values from 8 consecutive samples shall exceed the higher value.

	Standard Value		
	Summer	Winter	Winter
Faecal Coli MPN/100ml	5000	20,000	30,000

