

May - July 2009		POND SIX	POND SIX	POND SIX
		Enterococci	E.coli	Faecal Coliforms
Day	Date	MPN/100ml	CFU/100ml	CFU/100ml
Thursday				
Monday	04.05.2009	15	1500	1200
Thursday	07.05.2009	310	600	620
Monday	11.05.2009	120	560	710
Thursday	14.05.2009	31	740	760
Monday	18.05.2009	10	420	720
Thursday	21.05.2009	230	620	700
Monday	25.05.2009	350	1000	1700
Thursday	28.05.2009	37	290	330
Monday	01.06.2009	<10	420	240
Thursday	04.06.2009	20	440	500
Monday	08.06.2009	<10	240	120
Thursday	11.06.2009	31	160	200
Monday	15.06.2009	36	180	200
Thursday	18.06.2009	26	700	560
Monday	22.06.2009	130	1700	900
Thursday	25.06.2009	74	960	1600
Monday	29.06.2009	31	290	380
Thursday	02.07.2009	31	560	440
Monday	06.07.2009	96	230	270
Thursday	09.07.2009	63	100	180
Monday	13.07.2009	<20	200	150
Thursday	16.07.2009	36	220	190
Monday	20.07.2009	10	35	20
Thursday	23.07.2009	20	140	100
Monday	27.07.2009	20	40	60
Thursday	30.07.2009	31	80	100

Consent Requirements Condition 16(d)

Based on twice weekly sampling no more than 6 values from 8 consecutive samples shall exceed the following standard values and no more than 2 values from 8 consecutive samples shall exceed the higher value.

	Standard Value		
	Summer	Winter	Winter
Faecal Coli MPN/100ml	5000	20,000	30,000