

Mass Loadings Pond 6		BOD5	BOD5 Dissolved	Suspended Solids	Reactive Phosphorus
Consent Standard		5400	1800	8100	1260
Date	Flow	kg/day	kg/day	kg/day	kg/day
04.05.2009	88,190	1676	212	4145	406
07.05.2009	241,156	9164	844	10129	
11.05.2009	296,907	4454	505	10986	1158
14.05.2009	199,776	2198	659	5993	639
18.05.2009	178,183	1711	748	5345	517
21.05.2009	298,400	4178	1134	11041	776
25.05.2009	233,498	1751	490	5370	537
28.05.2009	280,496	3366	841	9817	
01.06.2009	0	0	0	0	0
04.06.2009	181,464	1307	381	3448	472
08.06.2009	152,109	456	114	2890	472
11.06.2009	179,699	1078	485	4133	
15.06.2009	190,949	1909	143	4583	535
18.06.2009	183,566	1707	385	8077	642
22.06.2009	196,263	1236	510	3533	667
25.06.2009	182,955	1482	384	2927	695
29.06.2009	166,868	1302	284	3671	617
02.07.2009	124,246	857	248	2982	460
06.07.2009	197,778	2967	653	6329	672
09.07.2009	198,811	2187	457	5368	636
13.07.2009	160,614	1927	578	4015	594
16.07.2009	178,992	2506	465	4654	662
20.07.2009	177,671	746	133	1777	586
23.07.2009	153,739	2152	1061	5227	538
27.07.2009	191,151	1376	1013	5735	593
30.07.2009	166,719	2167	400	6335	