

Aug - Oct 2009		POND SIX	POND SIX	POND SIX
		Enterococci	E.coli	Faecal Coliforms
Day	Date	MPN/100ml	CFU/100ml	CFU/100ml
Thursday				
Monday	03.08.2009	20	40	<20
Thursday	06.08.2009	20	<20	80
Monday	10.08.2009	25	140	150
Thursday	13.08.2009	130	20	<20
Monday	17.08.2009	20	80	60
Thursday	20.08.2009	<10	70	80
Monday	24.08.2009	<10	80	50
Thursday	27.08.2009	10	60	45
Monday	31.08.2009	<41	180	170
Thursday	03.09.2009	64	260	440
Monday	07.09.2009	10	100	60
Thursday	10.09.2009	<10	20	60
Monday	14.09.2009	41	280	140
Thursday	17.09.2009	10	60	120
Monday	21.09.2009	1,700	165	195
Thursday	24.09.2009	25	175	140
Monday	28.09.2009	31	80	55
Thursday	01.10.2009	31	110	100
Monday	05.10.2009	21	200	147
Thursday	08.10.2009	<10	170	190
Monday	12.10.2009	97	800	230
Thursday	15.10.2009	10	180	220
Monday	19.10.2009	30	1600	1800
Thursday	22.10.2009	41	650	520
Monday	26.10.2009	5	950	650
Thursday	29.10.2009	30	560	300

Consent Requirements Condition 16(d)

Based on twice weekly sampling no more than 6 values from 8 consecutive samples shall exceed the following standard values and no more than 2 values from 8 consecutive samples shall exceed the higher value.

	Standard Value		
	Summer	Winter	Winter
Faecal Coli MPN/100ml	5000	20,000	30,000