

Mass Loadings Pond 6		BOD5	BOD5 Dissolved	Suspended Solids	Reactive Phosphorus
Consent Standard		5400	1800	8100	1260
Date	Flow	kg/day	kg/day	kg/day	kg/day
03.08.2009	156,100	1561	375	4371	500
06.08.2009	160,292	1924	609	7213	513
10.08.2009	157,905	3474	426	5527	490
13.08.2009	221,251	5310	996	7080	443
17.08.2009	177,312	1223	301	4078	674
20.08.2009	181,019	1991	326	3439	670
24.08.2009	158,937	1526	413	7152	509
27.08.2009	180,693	1409	136	11022	470
31.08.2009	211,837	4449	381	14405	530
03.09.2009	162,879	1955	277	11890	456
07.09.2009	153,529	2149	322	13050	415
10.09.2009	125,589	3642	402	9922	276
14.09.2009	166,595	3665	1383	13161	500
17.09.2009	214,847	5586	1074	12246	537
21.09.2009	150,966	3472	574	4982	604
24.09.2009	149,101	1640	388	3280	760
28.09.2009	124,580	897	262	2367	523
01.10.2009	157,981	1185	664	3160	648
05.10.2009	148,343	890	252	4895	475
08.10.2009	192,640	1445	144	7513	597
12.10.2009	133,535	1469	1229	6810	374
15.10.2009	164,457	1809	395	10525	658
19.10.2009	144,861	3042	377	10720	435
22.10.2009	163,871	1966	279	13437	410
26.10.2009	140,699	3236	1548	12522	295
29.10.2009	226,038	4973	1627	20795	723