

Feb - April 2010		POND SIX	POND SIX	POND SIX
		Enterococci	E.coli	Faecal Coliforms
Day	Date	MPN/100ml	CFU/100ml	CFU/100ml
<i>Thursday</i>				
<i>Monday</i>	02.11.2009	20	260	300
<i>Thursday</i>	05.11.2009	20	140	140
<i>Monday</i>	09.11.2009	<10	<10	<10
<i>Thursday</i>	12.11.2009	83	80	80
<i>Monday</i>	16.11.2009	41	160	100
<i>Thursday</i>	19.11.2009	<1	40	40
<i>Monday</i>	23.11.2009	20	80	220
<i>Thursday</i>	26.11.2009	20	20	100
<i>Monday</i>	30.11.2009	130	340	250
<i>Thursday</i>	03.12.2009	20	160	140
<i>Monday</i>	07.12.2009	10	60	40
<i>Thursday</i>	10.12.2009	10	180	140
<i>Monday</i>	14.12.2009	31	90	70
<i>Thursday</i>	17.12.2009	31	200	130
<i>Monday</i>	21.12.2009	41	520	420
<i>Thursday</i>	24.12.2009	52	40	100
<i>Monday</i>	28.12.2009	52	160	80
<i>Thursday</i>	31.12.2009	20	100	280
<i>Monday</i>	04.01.2010	20	260	240
<i>Thursday</i>	07.01.2010	380	900	540
<i>Monday</i>	11.01.2010	<10	240	180
<i>Thursday</i>	14.01.2010	73	340	240
<i>Monday</i>	18.01.2010	52	100	160
<i>Thursday</i>	21.01.2010	240	400	280
<i>Monday</i>	25.01.2010	160	640	940
<i>Thursday</i>	28.01.2010	30	100	80

Consent Requirements Condition 16(d)

Based on twice weekly sampling no more than 6 values from 8 consecutive samples shall exceed the following standard values and no more than 2 values from 8 consecutive samples shall exceed the higher value.

	Standard Value		
	Summer	Winter	Winter
Faecal Coli MPN/100ml	5000	20,000	30,000