

Mass Loadings Pond 6		BOD5	BOD5 Dissolved	Suspended Solids	Reactive Phosphorus
Consent Standard		5400	1800	8100	1260
Date	Flow	kg/day	kg/day	kg/day	kg/day
02.11.2009	245,659	2948	246	17687	884
05.11.2009	163,624	3272	164	6381	638
09.11.2009	152,556	1526	153	1983	809
12.11.2009	171,382	1594	171	1200	1080
16.11.2009	210,544	316	211	526	1242
19.11.2009	159,521	239	160	399	925
23.11.2009	144,751	217	145	2461	492
26.11.2009	71,878	582	72	1581	345
30.11.2009	184,190	2579	184	6078	534
03.12.2009	168,682	3036	169	4723	388
07.12.2009	272,245	3811	272	8440	626
10.12.2009	93,103	1210	93	3259	214
14.12.2009	238,872	1792	239	5494	1003
17.12.2009	84,103	303	84	1598	496
21.12.2009	253,145	2785	253	4050	1316
24.12.2009	164,591	3150	165	5761	757
28.12.2009	103,906	1455	104	3948	582
31.12.2009	175,270	684	175	5784	719
04.01.2010	267,827	5464	268	14463	884
07.01.2010	73,310	1320	73	4399	315
11.01.2010	227,248	4636	227	14089	545
14.01.2010	224,613	3594	225	13028	562
18.01.2010	109,169	2565	109	6768	382
21.01.2010	156,282	2188	156	9064	594
25.01.2010	126,700	2281	127	3674	507
28.01.2010	152,756	1253	153	6110	0