



**CHRISTCHURCH**

CITY COUNCIL • YOUR PEOPLE • YOUR CITY

# **Christchurch Wastewater Treatment Plant**

## **Quarterly Monitoring Report**

**November - January 2019**

CHRISTCHURCH WASTEWATER TREATMENT PLANT • SHUTTLE DRIVE OFF PAGES ROAD  
PO BOX 73041 • CHRISTCHURCH • NEW ZEALAND • TEL 64-3-941-5701 • FAX 64-3-941-5729

File: Monitoring Report Nov - Jan 20199  
Contact: Lee Liaw

## Summary

This report summarises the results of parameters monitored by the Christchurch Wastewater Treatment Plant (CWTP) over the period November - January 2019 in accordance with consent CRC051724. Consent CRC051724 allows the discharge of treated wastewater from the CWTP Oxidation Ponds into the Pegasus Bay Coastal Marine Area via an ocean outfall.

Of the comprehensive sampling programme required by the consent, all samples were collected during the monitoring period and all monitored parameters achieved the required standards.

# Christchurch Wastewater Treatment Plant Contents

## Quarterly Monitoring Report

November - January 2019

<b>1</b>	<b>OUTFALL DISCHARGE .....</b>	<b>4</b>
1.1	<i>Resource Consent Conditions .....</i>	4
1.2	<b>Comments on Compliance.....</b>	4
1.3	<i>Resource Consent Standard Conditions.....</i>	6
1.4	<i>Comments on Compliance .....</i>	6
1.5	<i>Dissolved BOD<sub>5</sub> Compliance.....</i>	7
1.6	<i>Total Suspended Solids Compliance .....</i>	8
1.7	<i>Ammonia Nitrogen Compliance.....</i>	9
1.8	<i>Enterococci Monitoring .....</i>	10
1.9	<i>Faecal Coliform Compliance .....</i>	11
<b>2</b>	<b>RECEIVING ENVIRONMENT MONITORING IN PEGASUS BAY.....</b>	<b>12</b>
2.1	<i>Water Quality Resource Consent Conditions .....</i>	12
2.2	<i>Comments on Compliance .....</i>	12
2.3	<i>Beach Water Quality Analysis Results .....</i>	13
2.4	<i>Other Receiving Environment Analysis .....</i>	14
2.5	<i>Comments on Compliance .....</i>	14

# 1 Outfall Discharge

## 1.1 Resource Consent Conditions

Consent CRC051724 allows CWTP to discharge up to 518,000 cubic metres per day of treated wastewater from the CWTP Oxidation Ponds at a maximum rate of six cubic metres per second into the Pegasus Bay coastal marine area. Compliance conditions regarding the physical discharge to the estuary are summarised in Table 1.1.1. Daily records of maximum outfall discharge flow rates and volumes are attached as an appendix to this report, and shown in summary in Figures 1.2.1 and 1.2.2.

**Table 1.1.1** Pond Discharge Consent Compliance for Monitoring Period CRC051724


Consent Condition	Parameter	Compliance Condition	Compliance			
			Nov 18	Dec 18	Jan 19	Overall
2	Discharge Content	Discharge is only wastewater from the CWTP ponds	☺	☺	☺	☺
3	Discharge Volume	Recorded	☺	☺	☺	☺
4	Discharge Rate	Recorded	☺	☺	☺	☺
9	Outfall Maintenance	Routine maintenance completed and recorded	☺	☺	☺	☺
10	Outfall Condition	Visual inspection of outfall	n/a	n/a	n/a	n/a
12	Pumping Pressure for a given flow	Monitored	☺	☺	☺	☺

Key: ☺ Full Compliance    ☹ Minor, Isolated or Risk of Non-Compliance    ☹ Major or Consistent Non-Compliance

## 1.2 Comments on Compliance


Flowrate and pressure data were recorded as per consent requirements.

**CWTP Ocean Outfall Daily Flow Totals**



**Figure 1.2.1 - Daily Outfall Flow Totals**

**CWTP Ocean Outfall Peak Discharge Flow Rate (m3/s)**



**Figure 1.2.2 - Daily Peak Outfall Flows**

### 1.3 Resource Consent Standard Conditions

Conditions 15 and 16 of consent CRC051724 set out concentration standards for a selection of parameters monitored in compliance with condition 13. No more than 16 samples in each rolling 26 week period should exceed the standard value for contaminants listed under condition 15a, and if more than seven from eight consecutive samples should exceed the standard value ECan must be notified within 48 hours. No more than six from eight consecutive samples should exceed the standard value for contaminants listed under condition 16a, and no more than two from eight consecutive samples should exceed the higher value. If more than seven from eight exceed the standard value, or three from eight exceed the higher value, ECan must be notified within 48 hours. Compliance conditions regarding adherence to these standard values are summarised in Table 1.3.1. Analysis results are supplied to Environment Canterbury at quarterly intervals. Contaminant monitoring results for consent CRC051724 are discussed further in Sections 1.4 – 1.9.

**Table 1.3.1** Contaminant Limits Consent Compliance November – January 2019 CRC051724

Consent Condition	Parameter	Compliance Condition	Compliance			
			Nov 18	Dec 18	Jan 19	Overall
15a	Dissolved BOD <sub>5</sub>	Concentration does not exceed 20 g/m <sup>3</sup>	☺	☺	☺	☺
	Total Suspended Solids	Concentration does not exceed 50 g/m <sup>3</sup>	☺	☺	☹	☹
	Ammoniacal Nitrogen	Concentration does not exceed 40 g/m <sup>3</sup>	☺	☺	☺	☺
16a	Faecal Coliforms	Concentration does not exceed 1,000(standard)/5,000(higher) MPN/100mL	☺	☺	☺	☺
	Enterococci	Concentration does not exceed 1,500 MPN/100mL	☺	☺	☺	☺

Key: ☺ Compliance Achieved with no Exceedance of Standard    ☹ Compliance Achieved with Occasional Exceedance of Standard  
 ☹ Exceedance of Standard resulting in Non-Compliance

### 1.4 Comments on Compliance

All samples were collected and analysed. There was one exceedance of the total suspended solids standard, however this is not a non-compliance with the consent conditions.


### 1.5 Dissolved BOD<sub>5</sub> Compliance

The median dissolved BOD<sub>5</sub> concentration for the reporting period was 2.65g/m<sup>3</sup>. This is higher than the median concentrations in the previous quarter and higher than the same quarter in 2017. There were no exceedances of the standard value (20.0 g/m<sup>3</sup>) in the current monitoring quarter.

**Table 1.5.1** Pond Discharge Dissolved BOD<sub>5</sub>

Median Value [g/m <sup>3</sup> ] Current Monitoring Quarter (November 2018 – January 2019)	2.65	Number of Exceedances Current Monitoring Quarter (November 2018 – January 2019)	0
Median Value [g/m <sup>3</sup> ] Previous Monitoring Quarter (August 2018 – October 2018)	2.4	Number of Exceedances Previous Monitoring Quarter (August 2018 – October 2018)	0
Median Value [g/m <sup>3</sup> ] Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	1.7	Number of Exceedances Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	0

**1.5.2** Pond Discharge Dissolved BOD<sub>5</sub>




## 1.6 Total Suspended Solids Compliance

The median total suspended solids concentration for the monitoring period was 26 g/m<sup>3</sup>. This is higher than the previous quarter and higher than the same quarter last year. There was one exceedance of the standard value (50 g/m<sup>3</sup>) this quarter.

**Table 1.6.1** Pond Discharge Total Suspended Solids

Median Value [g/m <sup>3</sup> ] Current Monitoring Quarter (November 2018 – January 2019)	26	Number of Exceedances Current Monitoring Quarter (November 2018 – January 2019)	1
Median Value [g/m <sup>3</sup> ] Previous Monitoring Quarter (August 2018 – October 2018)	8.8	Number of Exceedances Previous Monitoring Quarter (August 2018 – October 2018)	0
Median Value [g/m <sup>3</sup> ] Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	19.5	Number of Exceedances Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	0

**1.6.2** Pond Discharge Total Suspended Solids






## 1.7 Ammonia Nitrogen Compliance

The median total ammonia nitrogen concentration for the monitoring period was 10.25 g/m<sup>3</sup>. This was lower than the previous quarter and lower than the same quarter last year. There were zero exceedances of the 40 g/m<sup>3</sup> limit.

**Table 1.7.1** Pond Discharge Ammoniacal Nitrogen

Median Value [g/m <sup>3</sup> ] Current Monitoring Quarter (November 2018 – January 2019)	10.25	Number of Exceedances Current Monitoring Quarter (November 2018 – January 2019)	0
Median Value [g/m <sup>3</sup> ] Previous Monitoring Quarter (August 2018 – October 2018)	27	Number of Exceedances Previous Monitoring Quarter (August 2018 – October 2018)	0
Median Value [g/m <sup>3</sup> ] Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	20.5	Number of Exceedances Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	0

**1.7.1** Pond Discharge Ammoniacal Nitrogen




## 1.8 Enterococci Monitoring

The median enterococci concentration during the reporting period was 30 MPN/100mL. This was higher than previous quarter and lower the same quarter last year. There were no exceedances of the 1,500 MPN/100ml limit during the reporting quarter.

**Table 1.8.1** Pond Discharge Enterococci

Median Value [g/m <sup>3</sup> ] Current Monitoring Quarter (November 2018 – January 2019)	30	Number of Exceedances Current Monitoring Quarter (November 2018 – January 2019)	0
Median Value [g/m <sup>3</sup> ] Previous Monitoring Quarter (August 2018 – October 2018)	<10	Number of Exceedances Previous Monitoring Quarter (August 2018 – October 2018)	0
Median Value [g/m <sup>3</sup> ] Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	31	Number of Exceedances Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	0

**1.8.1** Pond Discharge Enterococci




## 1.9 Faecal Coliform Compliance

The median concentration for the reporting period was 115 MPN/100 mL, which is higher than the median for the previous quarter, and higher than the same quarter last year. There were no exceedances of the standard faecal coliform limit.

Table 1.9.1 Pond Discharge Faecal Coliforms

Median Value [g/m <sup>3</sup> ] Current Monitoring Quarter (November 2018 – January 2019)	115	Number of Exceedances Current Monitoring Quarter (November 2018 – January 2019)	0
Median Value [g/m <sup>3</sup> ] Previous Monitoring Quarter (August 2018 – October 2018)	30	Number of Exceedances Previous Monitoring Quarter (August 2018 – October 2018)	0
Median Value [g/m <sup>3</sup> ] Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	105	Number of Exceedances Same Monitoring Quarter of Previous Year (November 2017 – January 2018)	0

1.9.1 Pond Discharge Faecal Coliforms



## 2 Receiving Environment Monitoring in Pegasus Bay

### 2.1 Water Quality Resource Consent Conditions

All samples were collected and analysed as required by consent condition 18. Samples for condition 18 are collected from South New Brighton Beach at Jellicoe Street, Sumner Beach at the surf club, and New Brighton at the Surf Club. Sampling for condition 22a is due February 2019.

**Table 2.1.1 Receiving Environment Water Quality Consent Compliance**

Consent Condition	Parameter	Compliance Condition	Compliance
			Nov – Jan 19
18	Faecal Coliforms	Sampled and Analysed	☺
	Enterococci	Sampled and Analysed	☺
22a	Temperature	2 yearly	na
	DO	2 yearly	na
	Salinity	2 yearly	na
	Total Suspended Solids	2 yearly	na
	Nitrogen Oxides	2 yearly	na
	Ammoniacal Nitrogen	2 yearly	na
	Dissolved Reactive Phosphorus	2 yearly	na
	Chlorophyll-a	2 yearly	na
	Trace Metals	2 yearly	na
	Faecal Coliforms	2 yearly	na
	Enterococci	2 yearly	na
	Phytoplankton Species	2 yearly	na

Key: ☺ Full Compliance    ☹ Minor, Isolated or Risk of Non-Compliance    ☹ Major or Consistent Non-Compliance


### 2.2 Comments on Compliance

All results for the Pegasus Bay area were within consent for the recording period.


*Beach Water Quality Analysis Results*

Samples for condition 18 were taken at weekly intervals from the prescribed onshore locations. Results are presented in Figures 2.3.1 and 2.3.2. Any retest results are contained in the appendices.

**2.2.1 Enterococci Levels at beaches adjacent to the Outfall**



**2.2.2 Faecal Coliform Levels at beaches adjacent to the Outfall**



### 2.3 Other Receiving Environment Analysis

Consent conditions 23, 25, 26 and 27 call for monitoring of the marine environment around the outfall at various frequencies, some of which fall in the monitoring period. These requirements are summarised in Table 2.4.1, and the results are attached as an appendix to this report. Sampling for Conditions 23 – 26 are due 2017 but was delayed and completed in early 2018, while condition 36 is now only undertaken if requested by members of the community.

**Table 2.3.1** Receiving Environment Monitoring Consent Compliance

Consent Condition	Parameter	Frequency	Compliance Condition	Compliance
				Nov – Jan 19
23	Marine Sediments	5-yearly	Not monitored this quarter	—
25	Benthic Invertebrates	5-yearly	Not monitored this quarter	—
26	Epibenthic Fauna	5-yearly	Not monitored this quarter	—
27	Shellfish	Quarterly	Sampled and analysed	☺
29	Complaints	As required	Recorded and reported	☺
31	Report	Quarterly and Annually	Report and information lodged with ecan	☺
36	Community Liaison Group	Annually	Not done this quarter	—

Key: ☺ Full Compliance    ☹ Minor, Isolated or Risk of Non-Compliance    ☹ Major or Consistent Non-Compliance

### 2.4 Comments on Compliance

No complaints regarding the ocean outfall have been received this quarter. This report and supporting documentation will be submitted to Environment Canterbury.